



PASADENA WATER AND POWER

Laboratory Report


Client: Arroyo Seco Foundation  
201 S. Lake Avenue, Ste 703  
Pasadena, CA 91101  
Attn: Mr. Andrew Byrne

Date Sampled: 11/28/07  
Date Received: 11/28/07  
Date of Analysis: 11/28/07-11/29/07  
Analysts: MY/RE

| Sample I.D.        | Chemistry I.D. | pH   | Turbidity (NTU) | NO3-N (ppm) | Microbiology I.D. | Total Coliform* | E-Coli     |
|--------------------|----------------|------|-----------------|-------------|-------------------|-----------------|------------|
| 1-1 Confluence     | 423339         | 8.10 | 0.5             | 4.00        | 0711209           | >200.5 MPN      | >200.5 MPN |
| 1-2 North Branch   | 423340         | 8.02 | 0.35            | 7.62        | 0711210           | QNS             | QNS        |
| 2-1 Golf Course    | 423341         | 8.15 | 4               | 2.45        | 0711211           | >200.5 MPN      | >200.5 MPN |
| 2-2 San Rafael     | 423342         | 8.27 | 2.5             | 1.30        | 0711212           | >200.5 MPN      | >200.5 MPN |
| 3-3 BFI Outlet     | 423343         | 7.98 | 0.3             | 2.76        | 0711213           | >200.5 MPN      | 50.4 MPN   |
| 3-2 Slime Slide    | 423344         | 7.99 | 2.5             | 3.46        | 0711214           | >200.5 MPN      | 118.4 MPN  |
| 3-3 Seco St. Drain | 423345         | 8.12 | 0.7             | 8.38        | 0711215           | >200.5 MPN      | 15.0 MPN   |
| 4-1 Flint Canyon   | 423346         | 7.96 | 0.8             | 2.72        | 0711216           | >200.5 MPN      | >200.5 MPN |
| 4-2 Altadena Drain | 423347         | 8.35 | 0.5             | 0.90        | 0711217           | >200.5 MPN      | >200.5 MPN |
| 5-1 Millard Canyon | 423348         | 7.93 | 0.15            | 1.71        | 0711218           | 200.5 MPN       | 65.9 MPN   |
| 5-2 El Prieto      | 423349         | 7.78 | 0.2             | 0.22        | 0711219           | 200.5 MPN       | 129.8 MPN  |

\* Idexx Quanti-tray QNS = Quantity Non Sufficient

Submitted by:

  
Diane Ayson-Fitzsimmons  
Laboratory Director  
City of Pasadena Water Quality Laboratory